

Prüfbescheinigung Declaration of Conformity

Antragsteller: Victron Energy B.V.
Applicant: De Paal 35; 1351 JG Almere Haven
Netherlands

Produkttyp: Inverter charger
Product type:

Model Overview				
	DC IN	AC OUT	AC IN	DC OUT
Multiplus 12/3000/120-16	9,5-17V; 250A	225-235V; 11A; 50Hz	187-250V; 16A; 45-55Hz	13,2-14,1V; 120A
Multiplus 12/3000/120-50	9,5-17V; 250A	225-235V; 11A; 50Hz	187-250V; 50A; 45-55Hz	13,2-14,1V; 120A
Multiplus 24/3000/70-16	19-33V; 125A	225-235V; 11A; 50Hz	187-250V; 16A; 45-55Hz	26,4-28,8V; 70A
Multiplus 24/3000/70-50	19-33V; 125A	225-235V; 11A; 50Hz	187-250V; 50A; 45-55Hz	26,4-28,8V; 70A
Multiplus 24/5000/120-50	9,5-17V; 250A	225-235V; 11A; 50Hz	187-250V; 50/30A; 45-55Hz	13,2-14,1V; 120A
Multiplus 24/5000/120-100	9,5-17V; 250A	225-235V; 11A; 50Hz	187-250V; 50/50A; 45-55Hz	13,2-14,1V; 120A
Quattro 12/3000/120-50/30	9,5-17V; 458A	225-235V; 11A; 50Hz	187-250V; 50/30A; 45-55Hz	13,2-14,1V; 120A
Quattro 12/3000/120-50/50	9,5-17V; 250A	225-235V; 11A; 50Hz	187-250V; 50/50A; 45-55Hz	13,2-14,1V; 120A
Quattro 12/5000/220-100/100	9,5-17V; 458A	225-235V; 11A; 50Hz	187-250V; 100/100A; 45-55Hz	13,2-14,1V; 220A
Quattro 24/3000/70-50/30	19-33V; 125A	225-235V; 11A; 50Hz	187-250V; 50/30A; 45-55Hz	26,4-28,8V; 70A
Quattro 24/5000/120-50/30	19-33V; 239A	225-235V; 18,5A; 50Hz	187-250V; 50/30A; 45-55Hz	26,4-28,8V; 120A
Quattro 24/5000/120-100/100	19-33V; 239A	225-235V; 18,5A; 50Hz	187-250V; 100/100A; 45-55Hz	26,4-28,8V; 120A
Quattro 24/8000/200-100/100	19-33V; 381A	225-235V; 29,5A; 50Hz	187-250V; 100/100A; 45-55Hz	26,4-28,8V; 200A

Ein repräsentatives Prüfmuster des oben genannten Modells bestand die Prüfung nach:
A representative test sample of above stated model passed the tests according to:

Norm: IEC 60335-2-29:2002 (Fourth Edition) + A1:2004 + A2:2009 in conjunction
Standard: with IEC 60335-1:2010 (Fifth Edition)) and EN60335-2-29:2004 + A2:2010

Berichtsnummer: 15PP104-01_0
Report no:

Zertifikatsnummer: 15-204-00
Certificate no:

Ausstelldatum: 2015-10-22
Date of issue:



Valentin Haug